



ALL TRENCHING SHALL BE 24" WIDE UNLESS CIRCUMSTANCES DICTATE OTHERWISE

# SECONDARY ELECTRIC COVER SHALL BE 36" WITH 2 1/2" SCHEDULE 40 PVC CONDUIT  
 \*FIBER OPTIC COVER SHALL BE 36" WITH 3" SCHEDULE 40 PVC CONDUIT  
 STREET LIGHT TRENCH COVER SHALL BE 36" WITH 1" SCHEDULE 40 PVC CONDUIT

NOTES:

1. DEPTHS SPECIFIED ARE TO FINISHED GRADE
2. OVER EXCAVATE AS NECESSARY TO ALLOW FOR (A) SAND BEDDING OR (B) LOOSE SANDY SOILS OR (C) WHERE MORE THAN ONE CABLE WILL BE INSTALLED IN TRENCH AND LAYING OF FIRST CABLE MAY CAUSE TRENCH DAMAGE AND REDUCTION IN DEPTH
3. NO PULL SHALL BE GREATER THAN 900' WITHOUT USE OF A PULL BOX
4. A MAXIMUM OF FOUR SWEEPING ELLS WILL BE ACCEPTED IN ONE PULL.
5. ALL TRENCHING WHICH REQUIRES MORE THAN ONE RUN OF CONDUIT WILL REQUIRE A TRENCH OF 24".
6. ROAD CROSSINGS REQUIRE SCHEDULE 80 PVC.
7. TRENCHING WILL BE INSPECTED BY DMU, AND MUST COMPLY WITH DMU SPECIFICATIONS BEFORE CONDUIT IS COVERED.

**ORRVILLE**  
**UTILITIES**

UNDERGROUND PRIMARY/SECONDARY & COMMUNICATIONS TRENCHING REQUIREMENT

D.G. DMUSPECS.DWG  
 11/21/96 A-4  
 NONE

ED-102596-1